

<b>FIRE LANE DESIGN &amp; SIGNAGE REVISIONS</b>		
<b>Revision Date</b>	<b>Section</b>	<b>Summary of Change</b>
2/16/11	All	Replaced all occurrences of “Occupational” with “Environmental”
2/16/11	Heading	Updated title
2/16/11	General Information	Updated information in numbers 1, 3 and 4

## **FIRE LANE DESIGN AND SIGNAGE**

### **UNIVERSITY CONTACT:**

Environmental Health & Safety  
(302) 831-8475

### **GENERAL INFORMATION: FIRE LANE SIGNAGE - Design Attached**

1. Two (2) Fire Lane Location Plans shall be submitted to the city of Newark; one (1) for the Fire Marshall to keep, one (1) for him to stamp "APPROVED" and return to FP&C for distribution. Plan shall include the following:
  - a. Scaled drawing showing all new and existing structures
  - b. Intended use of building(s)
  - c. Location of all fire hydrants and proposed sprinkler system water mains w/diameter
  - d. Maximum height of proposed building(s)
  - e. Proposed building construction
  - f. Note indicating if building will be protected by automatic sprinklers
  - g. Cross section of required fire barriers when applicable
2. FP&C Transmittals and copies of the approved Fire Lane Location Plans to:
  - a. EHS for their safety files
  - b. Public Safety for enforcement information
3. Original Fire Lane Location Plan approved by Authority Having Jurisdiction to be included in Project Drawing set.
4. All fire lanes shall comply with the Delaware State Fire Prevention regulations and/or Authority Having Jurisdiction, Part V Chapter 5 Standard for Fire Lanes and accessibility.

**APPROVED MANUFACTURERS:** N/A

**DO'S AND DON'TS:** N/A

**- END OF SECTION -**

