

SECTION 06 10 00 _ SUMMARY

University Contact: Structural Services, Maintenance & Operations (302) 831-8456

PART 1 – GENERAL

1.1 SUMMARY

- A. No content.

1.2 REFERENCES

- A. No content.

1.3 DESIGN REQUIREMENTS

- A. Blocking is required for all wall mounted items. This includes but is not limited to toilet accessories, door stops, handicap railings, etc.

PART 2 – PRODUCTS

- 2.1 No content.

PART 3- EXECUTION

- 3.1 No content.

PART 4 – ATTACHMENTS

- 4.1 No content.

End of Section

SECTION 05 20 00 & 06 43 00 _ SUMMARY

University Contact: Structural Services, Maintenance & Operations (302) 831-8456

PART 1 – GENERAL

1.1 SUMMARY

- A. No content.

1.2 REFERENCES

- A. No content

1.3 DESIGN REQUIREMENTS

- A. This applies to all interior and exterior handrails and guardrails.
- B. Interior handrails are to be stained wood, stainless steel or aluminum.
- C. Exterior handrails are to be stainless steel, aluminum, galvanized or wrought iron.

PART 2 – PRODUCTS

- 2.1 No content.

PART 3- EXECUTION

3.1 DO'S AND DON'TS

- A.
 - 1. DO have any deviations from the above standards approved by the University.
- B.
 - 1. DO NOT use extruded aluminum handrails or mechanically fastened material.
 - 2. DO NOT Insert posts into coping stones.
 - 3. DO NOT Core drill handrail posts closer than 6" from center line of post to edge of masonry.

PART 4 - ATTACHMENTS

- 4.1 No content.

End of Section