

**FIRE PROTECTION SYSTEM
RESIDENCE HALLS**

UNIVERSITY CONTACT:

Facilities Management
(302)831-4918

GENERAL INFORMATION:

The fire alarm systems for the Residence Halls to be approved by Housing Maintenance & Operations and Occupational Health & Safety

All new fire exit signs at residence halls to reviewed and approved by OH&S.
The material is to be Sentry Die Cast Aluminum L.E.D. Exit signs are to be vandal resistant and energy efficient.

APPROVED MANUFACTURERS:

Fire Alarm System: equipments and installation to be by Siemens Technologies

Exit Signs: Evenlite, Inc
3161 State road
Bensalem, Pa 19020
Tele: 800-872-0879
Fax: 215-244-4208
www.evenlite.com

DO'S AND DON'TS:

N/A

-- END OF SECTION --