

WALLS

UNIVERSITY CONTACT:

Structural Services, Maintenance & Operations
(302)831-8456

DESIGN REQUIREMENTS

All ancillary equipment such as, but not limited to, handrails, bookshelves, door bumpers, etc., shall be anchored to solid backing when attached to walls.

All gypsum board will be a minimum of 5/8 " thickness. Thickness and fire rating must adhere to applicable codes.

In drywall construction all outside corners in hallways, classrooms, laboratories and bathrooms to have exterior corner guards made of plastic as approved by UD, minimum width is 2".

In masonry construction, outside corners in high traffic areas to have corner guards made of plastic as approved by UD. Stainless steel corner guards may be used with approval by UD.

Reinforce metal stud partitions at shower enclosures in residence halls and at wall hung toilets in residence halls and academic buildings.

PREFERRED MANUFACTURERS: N/A

DO'S AND DON'TS: N/A

-- END OF SECTION --